



Attest-with-product certificate K92311/02

Issued 2017-03-17

Replaces K92311/01

Page 1 van 2

Legionella prevention with alternative techniques – Physical technique

STATEMENT BY KIWA

With this technical approval-with-product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Johs. Tandrup A/S

As specified in this attest-with-product certificate and marked with the Kiwa®-mark in the manner as indicated in "Marking" may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K14010 part 1 "Legionella prevention with alternative techniques – Physical technique" dated [21-03-2012].

Luc Leroy
Kiwa

Publication of the certificate is allowed.

Advice: consult www.1kiwa.com in order to ensure that this certificate is still valid.

CERTIFICATE

289170315

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 (0)88 998 44 00
Fax +31 (0)88 998 44 20
info@kiwa.nl
www.1kiwa.com

Company
Johs. Tandrup A/S
Gydevang 1
DK-3450 Allerød
Denmark
Tel. (+45) 48 17 22 82
Fax (+45) 48 17 73 55
tandrup@tandrup.dk
www.tandrup.dk

Certification process
consists of initial and
regular assessment of:

- quality system
- product

Legionella prevention with alternative techniques – Physical technique

Product specification

The products mentioned below belong to this attest-with-product certificate.

Product	Attest
<i>Model/Type:</i> T-Safe® Shower with filter: (MF filter system) - Wall shower - Hand shower	Installation instructions and manual T-Safe® Shower with filter At least drafted in Dutch (and English and Danish)
T-Safe® Tap Safe (MF filter system)	Installation instructions and manual T-Safe® Tap Safe with filter At least drafted in Dutch (and English and Danish)

Fitness for contact with drinking water

The pipes and fittings used in this system are not fully approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

Marking

The Kiwa®-mark products are marked with the word mark "KIWA" or 

Place of the mark: on the product itself

Required marking:

- Manufacturer or logo;
- Type of connection;
- Date of manufacture;
- Applied materials;
- Working pressure (PN);
- Capacity.

MF and UF filter

- Manufacturer membrane;
- Type of membrane and pore size

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

The physical technique is for use in collective drinking water installations and hot tap water installations with a pressure not exceeding 1 MPa (10 bar) and a temperature specified by the manufacturer. The equipment associated with the physical technique in this certificate can be installed at the following locations:

- In the line immediately before a draw-off point (point-of-use concept).

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Johs. Tandrup A/S
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods